

PRESSURE TEST LOG

G.M. No. 148721 (Kettleman-Morro Bay gas line #178)Sheet No. 2 of PROJECT DESCRIPTION Gas test from Valve #2 to Valve #3 (Compressor located at Valve #1)

DATE	TIME	SUCTION PRESSURE	DISCHARGE PRESSURE	LOCATION	REMARKS
Aug. 10, 1962	5:00 P M	865	1,010	Valve #2	
	5:30	860	1,010		
	6:00	855	1,015		
	6:30	845	1,025		
	7:00	870	1,027		Compressor speed 1,600 RPM
	7:30	860	1,030		
	8:00	850	1,032		Check motor and add two quarts oil, grease compr.
	8:30	845	1,034		
	9:00	865	1,035		
	9:30	858	1,037		
	10:00	853	1,042		
	10:30	845	1,044		
	11:00	860	1,048		
	11:30	860	1,050		
	12:00 M	850	1,052		
Aug 11, 1962	12:30 A M	840	1,054		
	12:31 A M	840	1,054		Compressor shut down Close suction and discharge valves
	1:00	850	1,054		
	1:30	860	1,054		
	2:00	870	1,054		
	2:30 A M	870	1,054		Test completed

Line 306 Feat: 308-3923 MAOP05271072.tif